

PENDULUM TEST VALUE

Test Report

Customer: Surfacescape Group Ltd
Site: 29 Jubilee Road, Newtownards, BT23 4YH
Test Location: Laboratory Test
Surface Description: Sinai Egyptian Limestone - Honed & Tumbled
Operator: RB
Date of test: 31/10/2022
Slider used: Four S
Pendulum: TRRL Type Skid Tester (BS 7976-3)

Report No: PTV1727
Date Reported: 01/11/2022


results to: brian@surfacescape.co.uk

DRY TEST RESULTS

	Test Direction		
	A (90°)	B (180°)	C (45°)
Pendulum Test Value (PTV)	64	63	63

WET TEST RESULTS

	Test Direction		
	A (90°)	B (180°)	C (45°)
Pendulum Test Value (PTV)	42	38	40



Determination of Pendulum Test Value carried out in accordance with BS 7976-2:2002 + A1:2013